

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5083

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

**SUPER S-E-S Euro Profile Sashlock, S-O-S Oval Profile Sashlock,
S-5D-S 5 Lever Sashlock, BS-5D-S 5 Lever Sashlock,
S-3D-S 3 Lever Sashlock, S-U Upright Latch & S-B Bathroom Lock
See Annex A**

Intended use: For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Harmonised technical specification
Mechanical test evidence: WIL 321085, WIL 329386-1, WIL 329386-3, WIL 329386-5, WIL 329386-6 & WIL 329386-7 Fire test evidence: WF 169070 & WF 173876 iss.6		
Self-closing ability 5.4.2 Closing force	Grade 8: 200Kg door mass with 15N maximum closing force.	EN 12209:2003 / AC:2005
5.1.2 Return force of latch bolt	>2.5N	
Durability of self-closing action 5.3.1 Durability of latch action	Grade S: 200,000 cycles with 50N side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire 5.2.1 Resistance to side load on latch bolt	Grade 3: 3kN	
5.5 Suitability for use on fire/smoke doors	Grade 1: suitable for use on fire/smoke resistant door assemblies	
Control of dangerous substances 5.1.1 Dangerous substances	Pass: The materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5083

Placed on the Market under the Name of

**Micota Tech (China) Co., Ltd.
No. 888 Yanjia Road
Yuantong St.
Haiyan Jiaxing
Zhejiang Province
China
PC 314317**

and produced in the manufacturing plant

E014136-1

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

EN 12209:2003 / AC:2005

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **30/11/2020** and re-issued on **24/04/2024** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **28/11/2026**

ERO Project Reference: **ERO 034621 P2288**



Pascal Coget
General Manager – European Certification

CSF408-NL 8.0

Certificate of Constancy of Performance

2812-CPR-AG5083

Annex A

Model No.	Description	Backset	Centres
S-E-64S S-E-76S	64mm SUPER Euro Profile Sashlock 76mm SUPER Euro Profile Sashlock	44.5mm 57.0mm	47.5mm
S-O-64S S-O-76S	64mm SUPER Oval Profile Sashlock 76mm SUPER Oval Profile Sashlock	44.5mm 57.0mm	48.5mm
S-5D-64S S-5D-76S	64mm SUPER 5 Lever Sashlock 76mm SUPER 5 Lever Sashlock	44.5mm 57.0mm	57.0mm
BS-5D-64S BS-5D-76S	64mm SUPER 5 Lever Sashlock 76mm SUPER 5 Lever Sashlock	44.5mm 57.0mm	57.0mm
S-3D-64S S-3D-76S	64mm SUPER 3 Lever Sashlock 76mm SUPER 3 Lever Sashlock	44.5mm 57.0mm	57.0mm
S-U-64 S-U-76	64mm SUPER Upright Latch 76mm SUPER Upright Latch	44.5mm 57.0mm	n/a
S-B-64 S-B-76	64mm SUPER Bathroom Lock 76mm SUPER Bathroom Lock	44.5mm 57.0mm	47.5mm