

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AG7916

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

**SUPER S-E-S Euro Profile Sashlock,
SUPER S-O-S Oval Profile Sashlock, SUPER S-5D-S 5 Lever Sashlock,
SUPER BS-5D-S 5 Lever Sashlock, SUPER S-3D-S 3 Lever Sashlock,
SUPER S-U Upright Latch & SUPER S-B Bathroom Lock**

Intended use: For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Harmonised technical specification
	Mechanical test evidence: WIL 329386-7, 329386-1, 329386-3, 329386-6, 329386-5, 321085 Fire test evidence: WF 172876 issue 6	
Self-closing 5.4.2 Closing force 5.1.2 Re-latching force of latch bolt	Grade 8 = 200kg door mass with 15N maximum closing force >2.5N	EN 12209:2003/AC 2005
Durability of self closing 5.3.1 Durability of latch action	Grade S = 200,000 cycles with 50N side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire	Grade 1	
Control of Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the hinge do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AG7916

Placed on the market under the name of

**Micota Tech (China) Co. Ltd
No.888 Yanjia Road
Haiyan
Jiaxing
Zhejiang Province
PC 314317
China**

and produced in the manufacturing plant

J/018

This is coded format and the information is held by the Approved Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 12209:2003/AC 2005

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **29/11/2021** and re-issued on **21/04/2023** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **28/11/2024**



0087



Paul Duggan
Certification Manager

**Warringtonfire Testing and Certification Limited
Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK**